



NEW JERSEY WATER SUPPLY AUTHORITY

P.O. BOX 5196 • CLINTON, N.J. 08809 • (908) 638-6121 • (908) 638-5241 (FAX)

To: All Prospective Bidders

From: Julie Hajdusek
Manager, Contracts & Risk Management

Date: March 31, 2026

Subject: **ADDENDUM NO. 1: WSA R26029 CONSULTING SERVICES
FOR THE REHABILITATION OF THE SWAN CREEK CULVERT AND
AQUEDUCT ON THE DELAWARE AND RARITAN CANAL,
CITY OF LAMBERTVILLE, HUNTERDON COUNTY, NEW JERSEY**

Attached on the following pages is a copy of Addendum No. 1 to the Project.

Vendors submitting Proposals for the above-named Project shall take note of the following changes, additions, deletions, clarifications, etc. in the Contract Documents, which shall become a part of and have precedence over anything contrarily shown or described in the Contract Documents, and all such shall be taken into consideration and be included in the Vendor's Proposal. Where changes, additions, deletions, clarifications, etc. are made to portions of an article, paragraph, or subparagraph, the unaltered provisions of that article, paragraph, subparagraph, or clause shall remain in effect.

Receipt of this Addendum No. 1 must be acknowledged by your signature below. This signed form must be included with your proposal submission.

Thank you for your cooperation.

I acknowledge receipt of Addendum No. 1 to WSA-R26029, issued on March 31, 2026:

Name of Bidder

Firm Name

Signature

Date

ADDENDUM NO. 1

This Addendum supplements and amends provisions of the RFP/Contract Documents. All provisions, which are not so amended or supplemented, remain in full force and effect.

The following question was received in response to the RFP. An answer is provided:

Question 1

Can the Canal be shut down, and if so, for how long?

Clarification 1

The technical proposal shall take into account that the Canal cannot be shut down, or capacity altered in any way, for any amount of time.